



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS1A 13 09 82688 011

Certificate Holder: Dortek Ltd
St Marks Street
Hull
HU87ED
UNITED KINGDOM

Certification Mark:



Product: Fire Rated Swing Doors

Brand Name: Single Action Door

Model(s): F120 # SA GRP

Product Details: Integrity: 120 mins ; Insulation: 30 mins
A glass fibre reinforced plastic (GRP) single acting,
double leaf, vermiculite core based doorset with vision
panels
See CoC Appendix (1pg) for hardware use

Standard(s): SS 332:2007 CI 4

Country of Origin: Ireland, Malaysia

Test Report(s): See CoC Appendix (1pg)

Issued on: 2013-09-25

Valid until: 2016-09-24

Products listed under Class 1A must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 2

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv-sud-psb.sg

Vice-President (Certification Department)
TÜV SÜD PSB



PRODUCT LISTING SCHEME

APPENDIX

TO CERTIFICATE OF CONFORMITY NUMBER: CLS1A 13 09 82688 011

Date of Issue : 2013-09-25

Issued To : Dortek Ltd
St Marks Street
Hull
HU87ED
UNITED KINGDOM

Test Report(s) : WF No. 323589
WF Assessment No. 320164 Issue 4 (exclude the proposal to incorporate alternative sliding gear and door holding devices)

Product Details : See test/assessment reports mentioned for installation conditions

Hardware	Brand/Model	Test Report/Assessment Report/Opinion Letter
Door closers	Dorma TS 83 EN 3-6 surface mounted door closer	TÜV SÜD PSB No. S09MEC03537/IHN
Lever handles and knobs	ASSA 0119-0432 stainless steel AISI 316L lever handle (unsprung)	TÜV SÜD PSB No. 7191005949-MEC11/03-AMH
Mechanical locks and latches	ASSA 760 lock	TÜV SÜD PSB No. 7191005949-MEC11/02-AMH
Single axis hinges	RT H101 heavy duty stainless steel lift-off hinge	TÜV SÜD PSB No. S09MEC05308/JC
Cylinders for locks	ASSA R501 cylinder	TÜV SÜD PSB No. 7191005949-MEC11/01-AMH



Signed: _____
Vice President (Certification Department)
TÜV SÜD PSB



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS1A 13 09 82688 010

Certificate Holder: DorteK Ltd
St Marks Street
Hull
HU87ED
UNITED KINGDOM

Certification Mark:



Product: Fire Rated Sliding Doors

Brand Name: 40mm Sliding Door

Model(s): F120 # SL (40mm)

Product Details: Integrity: 120 mins ; Insulation: 30 mins
A glass fibre reinforced plastic (GRP) sliding single leaf,
vermiculite core based doorset with vision panel

Standard(s): SS 332:2007 CI 4

Country of Origin: Ireland, Malaysia

Test Report(s): See CoC Appendix (1pg)

Issued on: 2013-09-25

Valid until: 2016-09-24

Products listed under Class 1A must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 2

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv-sud-psb.sg

Charles
Vice-President (Certification Department)
TÜV SÜD PSB





PSB Singapore

PRODUCT LISTING SCHEME APPENDIX

TO CERTIFICATE OF CONFORMITY NUMBER: CLS1A 13 09 82688 010

Date of Issue : 2013-09-25

Issued To : Dortek Ltd
St Marks Street
Hull
HU87ED
UNITED KINGDOM

Test Report(s) : WF No. 323874
WF Assessment No. 320164 Issue 4 (exclude the proposal to
incorporate mortice locks)
Door holding devices shall have a fusible link to activate closing

Signed: _____
Vice President (Certification Department)
TÜV SÜD PSB



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS1A 13 09 82688 009

Certificate Holder: DorteK Ltd
St Marks Street
Hull
HU87ED
UNITED KINGDOM

Certification Mark:



Product: Fire Rated Sliding Doors

Brand Name: 60mm Sliding Door

Model(s): F120 # SL (60mm)

Product Details: Integrity: 120 mins ; Insulation: 90 mins
A glass fibre reinforced plastic (GRP) sliding single leaf,
vermiculite core based doorset with vision panel

Standard(s): SS 332:2007 CI 4

Country of Origin: Ireland, Malaysia

Test Report(s): See CoC Appendix (1pg)

Issued on: 2013-09-25

Valid until: 2016-09-24

Products listed under Class 1A must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 2

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv-sud-psb.sg

Vice-President (Certification Department)
TÜV SÜD PSB





PSB Singapore

PRODUCT LISTING SCHEME APPENDIX

TO CERTIFICATE OF CONFORMITY NUMBER: CLS1A 13 09 82688 009

Date of Issue : 2013-09-25

Issued To : Dortek Ltd
St Marks Street
Hull
HU87ED
UNITED KINGDOM

Test Report(s) : WF No. 323148
WF Assessment No. 320164 Issue 4 (exclude the proposal to
incorporate mortice locks & steel linings)
Door holding devices shall have a fusible link to activate closing

Signed: _____
Vice President (Certification Department)
TÜV SÜD PSB